

Cross Anchor Utility District Water Quality Report for 2025

Is my drinking water safe?

Yes, our water meets all of EPA's health standards. This report shows our water quality and what it means. Our constant goal is to provide you with a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water.

What is the source of my water?

Your water, which is treated surface water, is purchased from the City of Greeneville TN. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Cross Anchor Utility District sources rated as reasonably susceptible to potential contamination. An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Chad Wampler at 423- 639-5125.

How can I get involved?

Our Water Board meets on the second Monday of each month at 8:30 a.m. at 800 W. Andrew Johnson Hwy. Please feel free to participate in these meetings. The Commissioners of Cross Anchor Utility District serve four year terms. Vacancies on the Board of Commissioners are filled by appointment by the Greene County Mayor from a list of three nominees certified by the Board of Commissioners to the Greene County Mayor to fill a vacancy. Decisions by the Board of Commissioners on customer complaints brought before the Board of Commissioners under the District's customer complaint policy may be reviewed by the Utility Management Review Board of the Tennessee Department of Environment and Conservation pursuant to Section 7-82-702(7) of Tennessee Code Annotated.

Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Our parent company's water treatment processes are designed to reduce any such substances to levels well below any health concern.

Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Cross Anchor Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Exposure to Lead in drinking water can cause serious health effects in all age groups. Infants and children can have a decrease in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risk of heart disease, high blood pressure, kidney, or nervous system problems.

Lead service line inventory has been completed for the Cross Anchor Utility District and can be accessed at www.crossanchorutilitydistrict.com

Pharmaceuticals In Drinking Water

Flushing unused or expired medicines can be harmful to your drinking water. Learn more about disposing of unused medicines at www.tn.gov/environment/sustainability/programs/pharmaceuticals-takeback.html

Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 423-639-5125.

Water Quality Data

What does this chart mean?

- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL**: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG**: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **TT** - Treatment Technique or a required process intended to reduce the level of a contaminant in drinking water.
- **Nephelometric Turbidity Unit (NTU)** – nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **Ug/l** – Micrograms Per Liter
- **RTCR**- Revised Total Coliform Rule This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.
- 1.0 ppm is the lowest range of detection for lead

Unless otherwise noted, the data in this table is from sampling performed during the 2024 calendar year for Cross Anchor UD.

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (RTCR)	No	0		2025		0	< 2 positive samples	Naturally present in the environment
Finished Water Turbidity ^{1*}	No	0.11 NTU	0.02-0.11 NTU	Daily 2025	NTU	N/A	TT	Soil runoff
Copper ^{**}	No	0.0242 ppm 90th percentile	0.00553-0.0597 ppm	2023	ppm	1.3	AL=1.3 ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	No	0.71 ppm	0.57-0.71 ppm	2025	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead ^{**}	No	1.0 ppm 90th percentile	N.D.-1.0 ppm	2023	ppb	0	AL=15 ppb	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	No	6.13ppm	6.13ppm	2025	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM [Total trihalomethanes]	No	40.98 ppb	13.50-64.70 ppb	Quarterly 2025	ppb	N/A	80	By-product of drinking water chlorination

Haloacetic Acids (HAA5)	NO	28.47 ppb	9.86-39.10 ppb	Quarterly 2025	ppb	N/A	60	By-product of drinking water disinfection.
Total Organic Carbon***	No	1.42 ppm Achieved 26% Required 35%	0.727-1.42 Ppm	2025	ppm	TT	TT	Naturally present in the environment.
Chlorine	No	1.77 ppm Avg.	0.30-2.30 Ppm	2025	ppm	4	4	Water additive used to control microbes.

* 100% of our samples were below the turbidity limit. Turbidity is a measurement of the cloudiness of water. **During the most recent round of Lead and Copper testing, 0 out of 20 households sampled contained concentrations exceeding the action level for Lead. 0 out of 20 households sampled contained concentrations exceeding the action level for Copper.

***We have met all treatment technique requirements for Total Organic Carbon removal.

CROSS-CONNECTION EDUCATION

Over the next few months, the warm weather will bring people outdoors to work in their yards and gardens and begin getting swimming pools ready. The **Cross Anchor Utility District** would like to ensure that our customers are aware of the dangers associated with these activities. An ordinary **garden hose** is a common way to contaminate a water supply when the hose is submersed in any liquid or attached to certain devices used to spray pesticides or herbicides. This forms a **cross connection**. A cross connection is a situation where a possible source of contamination is directly linked to our public water system. If the end of your hose is connected to a chemical container, swimming pool or other contaminant during a water main break or fire, the substance can be siphoned back into the water system. This condition, known as **back siphonage**, could cause a public health hazard. Devices are available to prevent this problem; however the best solution is to always be careful how you use your water hose.

Please help us provide a safe supply of water to all of our customers. Remember; never place your water hose in anything you would not want to drink. For more information on cross connections and how to protect against them, call our office at 423-639-5125.